HARBORLINE ELECTRIC

Electrical safety program

Issued by Jordan Avery on January 12, 2026

Purpose

This program sets out how Harborline Electric keeps its crews safe around energized equipment. It applies to every employee and every job site.

De-energize first

Equipment is placed in an electrically safe work condition before work begins: disconnected, locked and tagged out, and tested for absence of voltage. Energized work requires a written permit signed by the owner.

Arc-flash labels

Every panel and switchgear section we service carries a current arc-flash label. Missing or outdated labels are reported as an issue on the day they are found.

Training

Every field employee completes electrical safety training on hire and every three years after, and signs an acknowledgment in Balebase.